

TEXTILNÍ ZKUŠEBNÍ ÚSTAV, s.p.
(TEXTILE TESTING INSTITUTE)

Notified body No. 1021

Václavská 237/6, 603 00 Brno, Czech Republic

issues



CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1021 - CPR – 016-1/16

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

Textile floor coverings: Product group 5B - WO/PA-ECT350-750

Material:	80% wool/ 20% polyamide
Primary backing:	polyester
Secondary backing:	felt – ecotrust 350-750
Technology:	tufted – cut pile

Products placed on the market under the name or trade mark of:

Manufacturer: **Ege Carpets A/S**
Industrivej Nord 25, DK-7400 Herning, Denmark
ID: CVR 38454218

Manufacture location: 1) Ege Carpets A/S - Industrivej Nord 25, DK-7400 Herning, Denmark
2) Ege Carpets A/S - Industrivej 3, DK-6510 Gram, Denmark

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard:

EN 14041:2004/ AC:2006 Resilient, textile and laminate floor coverings – Essential characteristics

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.


Products fulfil the essential characteristic **of reaction to fire: Class B_{f1} – s1**

The present certificate was issued on the basis of the protocol No. 1021/16/033 from 22.02.2016 and No. 1021/20/022 from 10.01.2020 issued by NB 1021 TZÚ Brno. Detailed description of product group is stated in Annex No. 1 of the certificate.

This certificate was first issued on February 22, 2016 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



Brno, 10.01.2020



RNDr. Pavel Malčík
Managing Director

SCOPE:

Group 5B - WO/PA-ECT350-750 (80% Wool/ 20% Polyamide / Felt – Ecotrust 350-750)

Group 5.1 (WO/PA-ECT350-750)		Tufted	Cut Pile
Class B_n – s1			
<i>Total weight</i>	3 350 – 3 900 g.m ⁻²	<i>Total thickness</i>	10,5 - 12 mm
<i>Pile weight</i>	1 400 g.m ⁻²	<i>Pile thickness</i>	5,5 – 6 mm
<i>Classification report</i>	VN710 162312.1 (19.11.2019)	<i>Classification</i>	EN 13501-1 + A1
<i>Products in group</i>	Highline 80/20 1400 ECT350 Highline 80/20 1400 ECT750		

Field of application	Horizontal laid floor coverings in form of tiles . The carpet is to be mounted on a substrate of Euroclass A1 _n or A2 _n with a density of at least 1350 kg.m ⁻³ . It is declared for installation with a polyacrylat - copolymer dispersion adhesive (Ege modular tackifier) or similar and for installation with “Eco Pad” fixation.
-----------------------------	---

TEST REPORTS and DOCUMENTATION:

<i>Product</i>	<i>Test report</i>	<i>Date</i>	<i>Accredited laboratory</i>	<i>Product documentation</i>
Highline 80/20 1400 ECT350	PF13351	20.7.2010	DBI	4.2.2016
Highline 80/20 1400 ECT750	PF12442cc		DBI	

